



- Preferred piping layout.
- 2. The temperature and pressure relief valve setting shall not exceed pressure rating of any component in the system.
- 3. Service valves are shown for servicing boiler. However, local codes shall govern their usage.
- 4. Factory supplied pump is sized based on 50 equivalent feet of piping. (supply and return)

LEGEND